

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3240-0801:216 Page 1 of 1

CATEGORY: Duct Smoke Detector Housing/Base

LISTEE: Radionics, A Div. Of Detection Systems Inc., 130 Perinton Parkway, Fairport NY 14450
Contact: Frank Mioduszewski (716) 223-4060 Fax (585) 421-4263

DESIGN: Model D340 duct smoke detector housing. The unit consists of a thermal plastic enclosure, listed open area detector Model D285DH (CSFM Listing No. 7272-0801:162) or D286 (CSFM Listing No. 7271-1062:164), a sampling and an exhaust tube. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 12/24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as duct detector housing for use with listee's separately listed fire alarm control units. Suitable for air velocity between 300-4000 ft/min.

XLF: 3240-1062:136

05-27-2002 BH



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 21, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager